



STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY

LANSING



LIESL EICHLER CLARK
DIRECTOR

GRETCHEN WHITMER
GOVERNOR

December 14, 2022

Kelli Onufrak, Assistant Water Supervisor
City of River Rouge
10600 West Jefferson Avenue
River Rouge, Michigan 48218

WSSN: 05690
County: Wayne
Supply: River Rouge

Dear Kelli Onufrak:

SUBJECT: Lead and Copper Monitoring of Drinking Water Taps

The Michigan Department of Environment, Great Lakes, and Energy (EGLE) received your results of lead and copper tap monitoring conducted between **June 1 and September 30, 2022**. The calculated 90th percentile values are listed below. Please retain this information for your records.

Action Levels	90 th Percentile Value	# of Sites Above Action Level	Range of Individual Results
Lead 15 parts per billion (ppb)	7 ppb	0	0 ppb-13 ppb
Copper 1.3 parts per million (ppm)	0.1 ppm	0	0.0 ppm-0.1 ppm